



Date 06/01/2021

CERTIFICAT DE CONFORMITE

PRODUIT	AIRPORT FOAM 3%
CLIENT	ALDINI
FOLIO/FACTURE	CD55022
NUMERO DE LOT	E 98 K
DATE DE FABRICATION	11-2020
CONCENTRATION	3%
QUANTITE	1 X 1000 = 1000 L

ANALYSES	RESULTATS	SPECIFICATIONS	METHODE
DENSITE (g/ml)	0,997	1 ± 0,010	CU-I/10/C
pH	8.07	6 à 8,5	CU-I/10/A
VISCOSITE (cSt)	2,0	1 à 3	CU-I/10/E
BAS FOISONNEMENT 6% (Eau Douce)	10	≥ 8,0	CU-I/10/H
DECANTATION 25%	2 mn 15	≥ 2 mn	CU-I/10/H
TENSION SUPERFICIELLE 6% (mN/m)	20,73	20 - 25	CU-I/10/Q

Produit conforme à nos spécifications.

VISA Q.C